



राष्ट्रीय ग्रामीण विकास एवं पंचायती राज संस्थान

(ग्रामीण विकास मंत्रालय, भारत सरकार)
राजेन्द्रनगर, हैदराबाद - 500 030 (भारत)

NATIONAL INSTITUTE OF RURAL DEVELOPMENT & PANCHAYATI RAJ

(Ministry of Rural Development, Government of India)

Rajendranagar, Hyderabad - 500 030 (India)

P.V. DAYANAND
EXECUTIVE ENGINEER.

EE/CMU/12-13/128.JE (Ele)
September 06, 2017.

NIQ NO: EE/NIRD/17-18/NIQ/7

Sub: repairs and maintenance of 315KVA transform for NIRD Campus.

NIRD is an organization of the ministry of Rural Development, Government of India located at Rajendranagar, Hyderabad-500 030. We are interested to work required are indicated below. Hence quotations should be sealed and submitted to undersigned on or before 13.9.17 by 3:00PM, Quotations will be opened at 3:30 PM on the same day in the presence of the prospective bidders who are present.

S. No	Description	Qty	Rate (in words)	Amount
1.	Filtration of transformer oil to improve the dielectric strength for 315 KVA transfer	1No		
2.	Charges for 315 KVA transformer arresting the leakage of oil from LV bushings by replacement of LV studs oil seal, washers top cover gaskets etc., and cable termination 300 sq.mm	1set		
3.	Replacement of breather assembly of transformer	1set		
4.	Replacement of conservator glass and gaskets.	1set		
5.	Supply and topping up of transformer oil	100 lts		
6.	Insulation resistance lest	1Nos		
7.	To & Fro transportation	LS		
Total				

(Rupees

)

P.T.O

फोन : 24008526, तार : ग्राविक, फैक्स : 91-040-24016500 / 24015277, ई-मेल : cit@nird.gov.in, nirdhy@hub.nic.in


Phone : 24008526, Grams : Gravik, Fax : 91-040-24016500 / 24015277, E-mail : cit@nird.gov.in, nirdhy@hub.nic.in

We care for the environment

Special Terms and Conditions:

1. The firms are requested to visit the site and verify the 315 KVA Transformers is kept open for inspection accordingly.
2. This rates quoted should be inclusive of taxes.
3. Material supplied should confirm to ISI standards
4. The material should be supplied at the site as directed by the Engineer -in-charge in good condition and nothing extra will be paid for transportation.
5. The work should be completed within 3 days after receipt of work order.

Yours faithfully,
For and on behalf of the Director General


Executive Engineer

7/9/12

Copy to:

1. All Notice Boards
2. Registrar & Director (Admn) for information.
3. Assistant Registrar (Estt) may kindly arrange to display in all Notice Boards
4. ITL for display in web site.